

RECOMMENDATIONS

GENERAL FIRE SAFETY MEASURES FOR EDUCATIONAL INSTITUTE.

1. The entire construction of the proposed building shall be conforming the relevant buildings rules of local Panchayet body & N.B.C.of India.
2. The accessibility of fire appliances to the buildings shall be conforming.
3. Necessary certificate should have to obtain from the appropriate authority, regarding constructional safety point of view.
4. No temporary structure of any kind shall be allowed to erect within the premises or to roof of the building, which can be used for educational purpose.
5. in the educational institute for the purpose of Mid-day meal and or Canteen the kitchen should be remote from main College building and/or must be permanent construction i.e. R.C.C. structure. No temporary structure shall be allowed for kitchen purpose adjacent to the class room or main building.
6. Electrical load/earthing shall be tested at regular interval. Socket shall be used in every joins of electrical wiring to avoid loose contract, suitable fuse/circuit breaker shall be placed in the circuit.
7. It is desirable to provide minimum two exit doors remote to each other in each class room and all class rooms shall lead directly to a corridor of minimum with 1.5 M without entering of any other room.
8. One attendant for every 100 or part thereof students shall be provided who will guide them during emergency evacuation to ensure their safety.
9. The educational institute having the facilities of Chemical Laboratories shall have professionally qualified laboratory assistant who will ensure that there is no spillage or leakage of any flammable/fuming/ toxic/corrosive chemicals. All such chemicals must be preserved in sealed container and kept isolated.
10. The laboratory using LPG in cylinders for the use of Bunsen Burner shall be kept under safety cap with looking after the use and before closing of the laboratory.
11. **EXIT REQUIREMENT :**
 - a) All the exits shall be free from any kind of obstruction.
 - b) All the exits & exits corridors shall be adequately illuminated.
 - c) Exit directional sign and floor numbers shall be displayed in the conspicuous places.
 - d) Lobby approach and stair cases shall be well ventilated and adequately illuminated.
 - e) Width of the stair cases preferably be not less than 1.5 M and ravel distance shall not be exceed 22.5 M from any point to the nearest exit or stair case.
 - f) Stair case landing or underneath the stair case shall be kept free and not be used for storage or any other purpose.
 - g) Stair case construction or escape route shall be non-combustible construction.
 - h) All the stair case shall be fully enclosed type.
 - i) One another stair case shall be constructed for emergency.
12. **FIRE PROTECTION :**
 - I) For every 600 sq. meters of floor area or part there of one 9 liters water expelling extinguisher with a minimum of two extinguishers per compartment/floor of the building. The extinguisher shall be so distributed over the entire area that a person shall have to travel not more than 25 M from any point to reach nearest extinguishers.
 - II) For every 100 sq. meters of floor area or part thereof one 4.5 kg. Carbon d oxide extinguisher with a minimum of 2 nos. of extinguishers per room /compartment in library and record room etc. The extinguishers shall be so distributed over the entire area that a person shall have to travel not more than 10 M from any point to reach the nearest extinguishers.

....p/2



GOVERNMENT OF WEST BENGAL
DEPARTMENT OF THE FIRE SERVICE
(For Building of all Categories)
13-D, Mirza Ghalib Street, Kolkata-16

Memo No. DT. D.F.S./1629/13

Dated, the 12/9/13

To

The Secretary,

Ayam Arnav Sikshan Samstha
Vill Ajodhya, P.O. Bankahi, Bardwan

Sub : Demand Notice under Section-11C of WBFS Act, 1950 as amended for
issue of Provisional N.O.C. for the Premises No. 10/NO-2712/383, KA. NO 1240/24
J.L. NO. 37, Mozza Shyambazar, P.S. Kamark, BDR.

Dear Sir / Madam,

With reference to the building application submitted in respect to the above proposed this is to inform you that the building permit along with the sanctioned plan will be issued subject to the payment of fee amount Rs. 10,000/-

You are hereby requested to remit the above amount immediately from the date of receipt of the notice.

Total Floor Area (in Sq. Mtr.) : 1501.57 sq. m.
Ground Floor Area (in Sq. Mtr.) : 750.53 sq. m.
Primari use Group : B (Education)
Total additional Floor Area : NA
Abutting Road width : NA
Amount in words : Ten Thousand only.

Mode of Payment :-

Treasury Challan drawn in favour of—"0070-Other Administrative Service-00-109-Fire Protection & Control-001-Fees under the West Bengal Fire Service Act-13-Licence Fees" (A/Cs Code : 0070-109-001-13) to be deposited in Treasury / RBI.

The Treasury / RBI Challan Receipt (in Original) should be submitted in this Office on receipt of the same Provisional N.O.C. will be issued.

Yours faithfully,

12/09/13
D. O. 'G' Divn.
W.B.F.S.